



NOTES:

CLASS 560-C-3250 CONCRETE

1.579 CU. FT. / L.F.

1 CU. YD. = 17.10 L.F.

MINIMUM PERMISSIBLE GRADE 0.50%

PROVIDE 3/8" LIP AT EDGE OF ASPHALT WITH 1/8" TOLERANCE

MINIMUM SUBGRADE COMPACTION 95% RELATIVE TO MAXIMUM (TOP 12-INCHES)

ALL GUTTER TO BE "FLOW TESTED" PRIOR TO FINAL PAVING

SEE STANDARD 126 FOR JOINT DETAILS

***ADA NOTE:**

1. SEE STANDARD 136 FOR REQUIREMENTS AT CURB RAMPS.

L:\Public Works - Engineering Standards\INDIO-120 5/19/2016 11:43 AM



Juan Raya 05/18/16
 JUAN RAYA, P.E. DATE
 CITY ENGINEER
 RCE 68510

REV.	DRAWN BY:	APP'D:	DATE:



6" CURB AND GUTTER

STANDARD PLAN No.:

120

MAY 2016