

NOTES:


NOT TO SCALE

1. THE MINIMUM WALL HEIGHT SHALL BE 6' FROM THE HIGHEST ADJACENT GRADE.
2. THE MINIMUM TOP OF FOOTING COVER SHALL BE 8".
3. RETAINING WALL SHALL BE REQUIRED WHEN DIFFERENCE IN GRADE, FROM ONE SIDE OF THE WALL TO THE OTHER, IS 12" OR MORE.
4. NO 6" SLUMP STONE ALLOWED.
5. IF THERE IS A SLOPE ADJACENT TO THE BLOCK WALL, SUFFICIENT LEVEL DISTANCE SHALL BE PROVIDED TO MAINTAIN THE 8" MINIMUM TOP OF FOOTING COVER.
6. CONTACT THE CITY OF INDIO BUILDING AND SAFETY DEPARTMENT FOR STRUCTURAL DESIGN CRITERIA AND PERMITTING, AND PLANNING DEPARTMENT FOR AESTHETICS CRITERIA.
7. TOP OF WALL, TOP OF FOOTING, AND FINISHED GRADE ELEVATIONS SHALL BE SHOWN ON GRADING PLANS.

L:\Public Works - Engineering Standards\INDIO-550 5/19/2016 12:33 PM



Juan Raya 05/18/16
 JUAN RAYA, P.E. DATE
 CITY ENGINEER
 RCE 68510



STANDARD GARDEN WALL

MAY 2016

REV.	DRAWN BY:	APP'D:	DATE:

STANDARD PLAN No.: **550**